
CERTIFICATE OF APPROVAL No CAF 5018

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

**Designated CERTIFIRE Approved Door Manufacturers
as modified by**

BADMAN & BADMAN (JOINERY) LIMITED

**The Drill Hall, Warne Road, Weston Super Mare,
North Somerset, BS23 3SD
Tel: 01934 644 122 Fax: 01934 628 189**

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

SCOPE OF APPROVAL

Approved for processing* of fire doors manufactured by CERTIFIRE approved companies as specified in this certificate: apertures; glazing of apertures and door frames

TECHNICAL SCHEDULE

TS10 Fire Resisting Door Assemblies with non- Metallic Leaves

Signed and sealed for and on behalf of CERTIFIRE



Sir Ken Knight
Chairman - Management Council
Page 1 of 3

Issued: 4th February 2014
Valid to: 3rd February 2019



CERTIFICATE No CAF 5018 BADMAN & BADMAN (JOINERY) LIMITED

GLAZED APERTURES and DOOR FRAMES (Premdor Crosby Limited)

1. This approval relates to the cutting of apertures with or without glazing in doors supplied by Premdor Crosby Limited and to the manufacture of doorframes. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section 2 of the Technical Standards (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

Premdor Crosby Certificate Number	Timber Door Product	Aperture Cutting	Glazing of Apertures	Manufacture of Frames	MDF Frames	Resizing & Relipping
CF195	Premdor Fireshield	✓	✓	✓	✓	✗
CF198	FD30 Moulded Skin Chipboard Core	✓	✓	✓	✓	✗
CF240	FD30 Premcore	✓	✓	✓	✓	✓
CF241	FD60 Premcore	✓	✓	✓	✗	✓
CF302	FD60 Flaxcore	✓	✓	✓	✗	✗
CF380	FD30 Tubecore Lite	✓	✓	✓	✓	✗
CF625	FD30 PremCORE Lite	✓	✓	✓	✓	✓

Note: The scope of approval and field of application for the doors is contained in the above referenced certificates.

4. Apertures, glazing and frames shall be in accordance with Premdor Crosby Limited construction specifications and data sheets for the above referenced products.
5. Processing is conducted in accordance with Premdor Crosby Limited procedures.
6. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
7. Inspection and surveillance of factory production control
8. The approval relates to on-going production.
9. Approved products carry both the original manufacturer's CERTIFIRE approval label and a second label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

CERTIFICATE No CAF 5018 BADMAN & BADMAN (JOINERY) LIMITED

GLAZED APERTURES and DOOR FRAMES (JELD-WEN Limited)

1. This approval relates to the cutting of apertures with or without glazing in doors supplied by JELD-WEN Limited and to the manufacture of doorframes. Subject to the undermentioned conditions, the doors will meet the requirements as detailed in the relevant certificates.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section 2 of the Technical Standards (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. The certified doors for which the cutting of apertures, subsequent glazing thereof and provision of frames is approved are as following:

JELD-WEN Certificate Number	Timber Door Product	Aperture Cutting	Glazing of Apertures	Manufacture of Frames	MDF Frames	Resizing & Relipping
CF160	FD30 Flush & Die Formed	✓	✓	✓	✓	✗
CF177	FD60 Flush	✓	✓	✓	✗	✗
CF192	FD30 Tubeboard	✓	✓	✓	✓	✗
CF179	FD60 Die-formed	✗	✗	✓	✗	✗
CF271	FD30 Doors	✓	✓	✓	✗	✓
CF331	FD60 Doors	✗	✗	✓	✓	✗
CF394	FD60 Doors	✗	✗	✓	✓	✓
CF433	FD30 Doors	✗	✓	✓	✓	✗
CF572	FD30 Doors	✗	✗	✓	✓	✗
CF573	FD30 Doors	✗	✗	✓	✓	✗
CF5143	FD30 Doors	✓	✓	✓	✓	✓

(Note: please specify any limitations or restrictions that you wish to apply in relation to this company's processing of your doors.)

4. Apertures, glazing and frames shall be in accordance with JELD-WEN UK Limited construction specifications and data sheets for the above referenced products.
5. Processing is conducted in accordance with JELD-WEN UK Limited procedures.
6. The process is approved on the basis of on-going certification of quality management system to ISO 9001:2008.
7. Inspection and surveillance of factory production control
8. The approval relates to on-going production.
9. Approved products carry both the original manufacturer's CERTIFIRE approval label and a second label identified with the processor's name and contact number, the CERTIFIRE name, or name and mark, together with the CERTIFIRE certificate number and a unique serial number.

Page 3 of 3 Signed



Issued: 4th February 2014
Valid to: 3rd February 2019